



NOTES:

1. WHEN NO GROUNDING ELECTRODE EXISTS, 5/8 IN. DIA. SOLID COPPER GROUNDING ROD, 8 FT. IN LENGTH, SHALL BE INSTALLED.
2. ANCHOR BOLTS SHALL BE CONTINUOUS AND HAVE A MINIMUM 1 IN. FREE THREAD.
3. FOUNDATION CAP SHALL BE CONCRETE OR GROUT AS DESIGNATED BY ENTITY ENGINEER.

PROFESSIONAL ELECTRICAL ENGINEER STAMP ON FILE		AGENCY APPROVED	C				
SPECIFICATION REFERENCE		UNIFORM STANDARD DRAWINGS CLARK COUNTY AREA					
501	PORTLAND CEMENT CONCRETE	SUPPLEMENTAL DRAWING					
623	TRAFFIC SIGNALS & STREETLIGHTING						
		MODIFIED EXISTING STREETLIGHT FOUNDATION FOR INSTALLATION OF UNDERGROUND CONDUIT					
		DATE 08-09-18	DWG. NO.	321.1.S1			