



NOTES

1. BARE COPPER GROUNDING CONDUCTOR SHALL BE LOOPED AROUND ANCHOR BOLTS ONE TIME AND CONNECTED TO EACH ANCHOR BOLT BEFORE CONTINUING DOWN TO THE GROUNDING PLATE.
2. IN AREAS WHERE R/W PERMITS, THE CONCRETE BASE SHALL BE PLACED AT THE BACK EDGE OF THE SIDEWALK.
3. REFER TO STD. DWG. 331 FOR SERVICE PEDESTAL SETBACK AND ORIENTATION.
4. WIRE SIZES ARE BASED ON UNDERGROUND FEED.
5. WIRE SIZES SHALL BE INCREASED FOR VOLTAGE DROP LIMITATION WHEN RUN IS LONG.

PROFESSIONAL ELECTRICAL ENGINEER STAMP ON FILE

AGENCY APPROVED



SPECIFICATION REFERENCE

UNIFORM STANDARD DRAWINGS
CLARK COUNTY AREA

501 PORTLAND CEMENT CONCRETE

SUPPLEMENTAL DRAWING

623 TRAFFIC SIGNALS & STREET LIGHTING

SERVICE PEDESTAL FOUNDATION
STREET LIGHTING

DATE 08-08-19 DWG. NO. 332.S2